

Qualification Certificate

Clean rooms RY 13 Čisté prostory RY 13 - 1. NP

No.: VÚO_24_ČP_12_OQ

User: Výzkumný ústav organických syntéz a.s., č. p. 296, Rybitví 533 54

Location: Building RY 13, 1. NP

Type of qualification: Revalidation in the range of operational qualification

Class number: D/K

HVAC system and parameters of clean rooms class „D“, especially level of airborne particulate cleanliness, **comply** with relevant legislation (VYR-32 SÚKL, EU GMP Annex 1 and ČSN EN ISO 14644) and prove correct functioning.

Validity of certificate **March 2025**.

Certificate issued and approved:

Date: 05-02-2024



Ing. Michaela Wimmerová
Quality Manager - junior